

Flint Residential Testing Report - results collected January 1, 2019 through January 9, 2019

Sample Number	Date Submitted	Analysis (Lead)	2 Bottle Kit			1 Bottle Kit	Analysis (Copper)	2 Bottle Kit			1 Bottle Kit	Street #	Street Name	City	Zip Code
			250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)		250 ml Bottle (PPB)	750 ml Bottle (PPB)	1 Liter Calculated	1 Liter (PPB)				
LI21344	1/4/2019	Lead	0	0	0		Copper	0	0	0		1013	BARNEY AVE	FLINT	48503
LI21346	1/4/2019	Lead	0	0	0		Copper	0	0	0		1502	BEGOLE ST	FLINT	48503
LI21887	1/9/2019	Lead	0	0	0		Copper	0	0	0		1005	DOWNEY ST	FLINT	48505
LI21884	1/9/2019	Lead	0	0	0		Copper	0	0	0		143	E BELVIDERE	FLINT	48504
LI21889	1/9/2019	Lead	0	10	7		Copper	0	0	0		2520	E COURT ST	FLINT	48502
LI21891	1/9/2019	Lead	3	4	4		Copper	0	0	0		224	E COURT ST #410	FLINT	48503
LI21005	1/2/2019	Lead	0	0	0		Copper	0	0	0		1016	GARLAND ST	FLINT	48503
LI21888	1/9/2019	Lead	0	0	0		Copper	90	70	80		3216	HAWTHORNE DR	FLINT	48503
LI21006	1/2/2019	Lead	0	0	0		Copper	0	90	70		2305	ILLINOIS AVE	FLINT	48506
LI21885	1/9/2019	Lead	0	0	0		Copper	90	0	0		1702	KENWOOD	FLINT	48503
LI21007	1/2/2019	Lead	0	0	0		Copper	0	0	0		3119	KIRKWOOD LANE	FLINT	48504
LI21008	1/2/2019	Lead	4	0	1		Copper	110	50	70		3119	KIRKWOOD LN	FLINT	48503
LI21348	1/4/2019	Lead	0	0	0		Copper	0	0	0		1811	MLKING AVE	FLINT	48503
LI21890	1/9/2019	Lead	3	0	0		Copper	310	0	80		1813	SPRINGFIELD ST	FLINT	48503
LI21004	1/2/2019	Lead	0	0	0		Copper	0	0	0		3711	SUNCREST DR	FLINT	48504
LI21003	1/2/2019	Lead	0	0	0		Copper	0	0	0		2506	THOM ST	FLINT	48506
LI21345	1/4/2019	Lead	0	0	0		Copper	0	0	0		128	W DEWEY	FLINT	48505
LI21886	1/9/2019	Lead	0	0	0		Copper	110	0	0		609	W YORK AVE	FLINT	48503
LI21347	1/4/2019	Lead	0	0	0		Copper	50	90	80		3818	WISNER	FLINT	48504

Notes:

ppb = parts per billion

Lead values exceeding 15 ppb and Copper results exceeding 1,300 are highlighted in red.

Sample results of "Not Detected" have been replaced with a numerical value of zero for ease of sorting.

Samples without a zip code did not have one provided on the accompanying paperwork.

*** indicate Invalid Zip Code